Alaska EPA Audit Questionnaire

Facility Name Soldstra Y Chevron Alaska ID Ak 518 City, Zip Soldstra, AK 99669 Facility Contact Mark Rozak - New owner
Inspection Date 4-11-08
Last 3rd Party Inspector Poul PederSon Last inspection Date 8 - 28 - 05
Compliance Issues At the time of the last inspection, was the facility in compliance? Yes No
Were these issues fixed? Yes No
Is the facility in compliance today? Yes No
If the facility is not in compliance:
a. Is this the same issue found at the last inspection? b. Is this a new issue? c. List all non-complaint issues Was a compliance action issued by EPA? Field Citation Field Notice Pass 1) Failure to provide annua Like tightness testing 2) Failure to tess Alcas
Was a compliance action issued by EPA?
Field Citation Field Notice Pass 2) Failure to tess ALCOS S Curvally
<u>Inspection Differences</u> Were there any differences between the 3 rd party's inspection and yours? Yes No
If there were differences, what were they?

comments: Owner claims he did not know that line tightness & ALLIS testing is required annually